

Transmittal

May 7, 2024

to: Bidders from: Amanda Matlock, CCS, CDT
 company: _____ title: Procurement Manager
 address: _____ tel: 843-735-5154

subject: Addendum Number 3
 Repair/Replace Roofing Systems – Conway Campus
 Owner Project Number: H59-6227-PD
 BEE Project Number: 23010A

The following items are attached and include a total of 3 pages including transmittal:

ITEM #	DATE	DESCRIPTION
I.	May 7, 2024	Addendum Number 3 (2 Pages)

If you have any questions or comments, please do not hesitate to contact me.

delivered by: www.hgtc.edu/purchasing

Addendum Number 3

May 7, 2024

Repair/Replace Roofing Systems – Conway Campus

Owner Project Number: H59-6227-PD

Prepared by:

The Building Envelope Enclosure Group
1226 Yeamans Hall Road, Suite C
Hanahan, SC 29410

To Bidders:

This Addendum forms a part of the Contract Documents and modifies the original Procurement Documents, as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of 2 pages and the attachments listed.

Changes to Prior Addenda:

1. There are no changes to Addendum Number 1 dated April 15, 2024.
2. There are no changes to Addendum Number 2 dated May 1, 2024.

Changes to Procurement Requirements:

3. None.

Changes to Contracting Requirements:

4. Base Bid repairs to Building 1100 and Alternate Number 1 for replacement cannot commence until after the Least Terns nesting season, which generally occurs from April 15 to July 31.

Changes to Specifications:

5. Section 07 55 27, Roof Replacement Modified Bitumen Sheet Roofing System, 1.01, C., 1.:
 - a. Change “1-inch” to read “1.5-inch”.

Changes to Drawings:

6. None.